



GREATER NOIDA INDUSTRIAL DEVELOPMENT AUTHORITY
Plot No.01, Sector Knowledge Park-IV, Greater Noida
Distt.- Gautam Budh Nagar (UP)


Ref.: H.D./2025/ 813

Date: 15/04/2025

SANITARY CONDITION CERTIFICATE

It is certified that an inspection team headed by **Senior Manager (Health)** from **Greater Noida Industrial Development Authority, Plot No.-1, Sector Knowledge Park-IV, Greater Noida-201310 PHED** inspected the Greater Noida Industrial Development Authority inspected **Grand International School**, Plot No. HS-42, 130 Meter Road, Eta-2, Greater Noida, Distt-G.B. Nagar (U.P.) on 04.04.2025 certified that **Grand International School**, Plot No. HS-42, 130 Meter Road, Eta-2, Greater Noida, Distt-G.B. Nagar (U.P.) maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid for **one year**.

Signature with Seal: 

Name : **Sunny Yadav**

Designation : Senior Manager (Health)

Name & Address of the Office / Department

Greater Noida Industrial Development Authority

Plot No. 1, Sector Knowledge Park-IV, Greater Noida

To

The Principal
Grand International School,
Plot No. HS-42, 130 Meter Road,
Eta-2, Greater Noida
Distt-G.B. Nagar (U.P.)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



Complete Analytical Solution
ISO 14001 : 2015 & ISO 9001 : 2015 Certified

SHREE RAM TESTING LABORATORIES

ISO 14001 : 2015 & ISO 9001 : 2015 Approved Laboratory

Lab: A-2/103, Site-V, UPSIDC Industrial Area, Kasna, Greater Noida-201306
H.O. 223, 2nd Floor, Living Style Mall, Jasola, New Delhi-110025

Mob: 9953984801, 9717160780, 9999024801, E-mail: stl.noida@gmail.com

E-mail: shrooramlab@yahoo.com, info@shrooramlab.com Website: www.shrooramlab.in

TEST REPORT

Issued to : M/s Grads International School F-3/14, Krishna Nagar, Krishna Nagar, East Delhi, Delhi, 110051	Report No.	W-210325-01
	Report date:	21/03/2025
	Sample Received:	21/03/2025
	Analysis date:	21/03/2025 to 24/03/2025
	Sampled By:	customer

Sample Description: Drinking Water

Received Sample in Sealed and marked Plastic Bottle

RESULT

Drinking Water-Essential Tests as per IS 10500:2012

S.N.	Parameters (Units)	Test Method	Results	Requirement as per IS: 10500-2012
1.	Odour	IS:3025(P-5) 2018	Unobjectionable	Unobjectionable
2.	Taste	IS:3025(P-8) 1984 (RA- 2017)	Agreeable	Agreeable
3.	Colour (Hazen)	IS:3025(P-4) 2021	<1.0	5 max
4.	Turbidity (NTU)	IS:3025(P-10) 1984 (RA- 2017)	Nil	1 max
5.	pH value (at 25 °C)	IS:3025(P-11) 1983 (RA- 2017)	6.85	6.5 to 8.5
6.	Total Dissolved solids (mg/l)	IS:3025(P-16) 1984 (RA- 2017)	53	500 max
7.	Total Hardness (as CaCO ₃) (mg/l)	IS 3025 P-21:2009 (RA- 2019)	20	200 max
8.	Chloride (as Cl) (mg/l)	IS:3025(P-32) 1988 (RA- 2019)	16.14	250 max
9.	Iron (as Fe) (mg/l)	IS:3025(P-53) 2003 (RA- 2019)	0.01	0.3 max
10.	Residual Free Chlorine(mg/l)	IS:3025(P-26) 2021	0.012	0.20 max
11.	Fluoride (as F) (mg/l)	APHA 4500 (D)	0.010	1.0 max
12.	Total Alkalinity (as CaCO ₃), (mg/l)	IS:3025(P-23)- 1986 (RA- 2019)	105	200 max
13.	Magnesium (as Mg), (mg/l)	IS:3025(P-46)- 1994 (RA- 2019)	4.38	30 max
14.	Aluminum (as Al) (mg/l)	IS:3025(P-55)- 2003 (RA- 2019)	Not Detected	0.03 max
15.	Zinc (as Zn), (mg/l)	IS:3025(P-49)- 1994 (RA- 2019)	0.01	5 max
16.	Lead (as Pb), (mg/l)	IS:3025(P-47)- 1994 (RA- 2019)	Not Detected	0.01 max
17.	Mercury (as Hg), (mg/l)	IS:3025(P-48)- 1994 (RA- 2019)	Not Detected	0.001 max
18.	Total Arsenic (as As), (mg/l)	IS:3025(P-37)- 1988 (RA- 2019)	Not Detected	0.01 max
19.	MICROBIOLOGICAL PARAMETERS			
i	Coliform (cfu/100ml)	IS 1622:1981 (RA- 2019)	Absent	0 max
ii	E. Coli (cfu/100ml)	IS 1622:1981 (RA-2019)	Absent	0 max

Remark: The Tested Parameters meet as per BIS specification.

END OF REPORT

TESTED BY
Strongh

AUTHORIZED
Technical Manager
SK Tiwari
[Signature]

Note:- (1) The above results are related only to the test performed on the sample, Endorsement to product is neither inferred. (2) This report is not to be reproduced wholly or in part & can not be used as an evidence in the court of law & should not be used in a any advertising media without special permission in writing (3) Sample will be destroyed after 30 days from the date of reporting unless otherwise specified.

(4) Total liability of our lab is limited to the invoice amount (5) report refers to the sample drawn by shree ram testing Laboratories unless mentioned otherwise